


Certificate of Compliance

Certificate Number 121005 - E257135
Report Reference E257135, September 9th, 2005
Issue Date 2005 October 12

Page 1 of 2



Issued to: BUERKLE & SCHOECK TRANSFORMATOREN GMBH
GEWERBESTRASSE 38
70565 STUTTGART GERMANY

This is to certify that representative samples of Three Phase Reactors
Models RWS 184-100-99, RWS 184-150-99, RWS 184-180-99-3, RWS 184-250-99

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 506 - Specialty Transformers
CSA C22.2 No. 66-1988 - Specialty Transformers

Additional Information: See Addendum for Ratings

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceeding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by: *Ronni Kulzinger*
Ronni Kulzinger, Team Ldr Engineer

UL International Germany GmbH

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Germany, you may call +49 0 6102 369 0.

Reviewed by: *Andreas Entzeroth*
Andreas Entzeroth, Group Ldr Engineer

UL International Germany GmbH

Certificate of Compliance

Certificate Number 121005 - E257135

Page 2 of 2

Report Reference E257135, September 9th, 2005

Issue Date 2005 October 12



**Underwriters
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR, cUR requirements.

Model	Max. Voltage, V	Max. Current, A	Frequency, Hz
RWS 184-100-99	3x 600	100	50/60
RWS 184-150-99	3x 600	150	50/60
RWS 184-180-99-3	3x 600	180	50/60
RWS 184-250-99	3x 600	250	50/60

Issued by:

Ronni Kulzinger, Team Ldr Engineer

UL International Germany GmbH

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International Germany GmbH

Reviewed by:

Andreas Entzeroth, Group Ldr Engineer

UL International Germany GmbH