


Certificate of Compliance

Certificate Number 200905 - E216181
Report Reference E216181, June 30th, 2005
Issue Date 2005 September 20

Page 1 of 2



Issued to: **Buerkle & Schoeck Transformatoren
GmbH - Gewerbestrasse 38
D-70565 Stuttgart Germany**

*This is to certify that
representative samples of*

**Systems, Electrical Insulation
Class 155(F) transformer insulation system designated BRU-2.**

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*



Standard(s) for Safety:

**UL 1446 - Systems of Insulating Materials - General
CSA C22.2 No. 0 - General Requirements - Canadian Electrical Code, Part II,
Appendix B**

Additional Information:

See Addendum for Electrical Ratings

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

Look for the UL Recognized Component Mark on the product

Issued by: *Sander Nieuwenhuijzen*
Sander Nieuwenhuijzen, Senior Project Engineer

Reviewed by: *Mirza Baig*
Mirza Baig, Staff Engineer

UL International (Netherlands) B.V.

UL International (Netherlands) B.V.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in Netherlands, you may call +31 0 318 581310.

Certificate of Compliance

Certificate Number 200905 - E216181
Report Reference E216181, June 30th, 2005
Issue Date 2005 September 20

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR, cUR requirements.

Ratings:

| System Designation | Insulation Class | Maximum Hot Spot Temperature | Indoor | Outdoor (Enclosed) | |
|--------------------|------------------|------------------------------|--------|--------------------|--|
| BRU-2 | 155(F) | 155°C | Yes | Yes | |
| | | | | | |

Issued by:

Sander Nieuwenhuijzen, Senior Project Engineer

UL International (Netherlands) B.V.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL International (Netherlands) B.V.

Reviewed by:

Mirza Baig, Staff Engineer

UL International (Netherlands) B.V.